## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

**LISTING No.** \*3226-1577:101 Page 1 of 1

CATEGORY: \*Ceiling Dampers

LISTEE: Ward Industries, A Division of Hart and Cooley, Inc., 11 Riverview Drive, Monessen, PA 15062

Contact: Mark Lauer (616) 546-3941 FAX (616) 392-4829

**DESIGN**: Models W50-CRD and W55-CRD ceiling dampers. Ceiling dampers function as a heat barrier

in air handling penetrations through fire resistive ceilings and are intended to maintain the fire resistive integrity of the ceiling. Frame, blades, hinges, and link plate are roll-formed No. 22

Ga. galvanized steel. Size limitations as follow:

ModelMax. Width x LengthMin. Width x LengthW50-CRD24" x 24"5" x 5"W55-CRD24" Diameter5" DiameterW55-CRD with16" Diameter5" Diameter

air diffuser

Refer to listee's printed data sheet for additional detailed product description, installation and

operational considerations.

**INSTALLATION**: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

**MARKING**: Listee's name, model number, and UL label.

APPROVAL: Listed as ceiling dampers for installation inside duct outlets and return air plenums in fire

resistive floor-ceiling or roof-ceiling assemblies with a restrained or unrestrained assembly

rating of 3 hours or less. \*Refer to listee's Installation Instruction Manual for details

**NOTE:** 1. Leakage rating not evaluated. Refer to CSFM Listing Category 3230 for listed leakage

dampers.

2. Formerly \*3225-1577:101

**XLF**: 3226-1417:101, Formerly 3225-1417:101

\*Corrected 02-26-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: FEBRUARY 26, 2004 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager